

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

# LISTING SERVICE

**LISTING No.** 7272-0028:208

Page 1 of 1

**CATEGORY:** Photoelectric Smoke Detector

**LISTEE:** Notifier, One Fire-Lite Place, Northford CT 06472-1653  
Contact: Larry Flood (203) 484-1200 Fax (203) 484-7309

**DESIGN:** Model FAPT-751 photoelectric type smoke detector. Each unit consists resistors, capacitors, diodes, transistors, microprocessor, LED, photoelectric chamber, mounted on a printed wiring board inside an enclosure which has an opening to the outside air. Unit also employs an integral heat sensor. This sensor is intended for use only as a supplemental to the smoke detector. Refer to listee's data sheet for detailed product description and operational considerations.

**RATING:** 24 VDC

**INSTALLATION:** In accordance with listee's printed instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, model designation, air velocity rating and UL label.

**APPROVAL:** Listed as smoke detectors for use with separately listed compatible bases and fire alarm control units. Suitable for open areas with air velocities between 0-4000 fpm.

09-21-2000



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

**JUNE 6, 2003**

*Listing Expires **June 30, 2004***

Authorized By:

**DIANE K. AREND**, Senior Deputy  
Program Manager